PENNONI ASSOCIATES INC.
CONSULTING ENGINEERS

THRN 01 00
October 12, 2017

# ENGINEER'S REPORT

REGARDING WASTEWATER ISSUES
October 18, 2017

## East Side Sewer District

### – Chemical Storage Tank @ WWTP

- The 1025 gallon tank housing the chemical required for phosphorus removal has developed a leak. The leak at this time is relatively minor, contained and does not present a hazard. The issue however will have to be addressed in the near future. We will work with Township staff and DELCORA to determine the most practical and cost effective solution.

### – Thornton Road Low Pressure Sewer

- E-mail comments from DEP relating to the planning module application were received on October 2nd. All comments were minor in nature. A response letter addressing these comments will be forwarded to DEP by the end of this week. We are also continuing with the preparation of plans and Part II Water Quality Management permit application.

## West Side Sewer District

### – Mill Creek Subdivision

- At this time, all construction related items contained in our punch list dated 10/1/13 have been addressed. The outstanding issues consist solely of revisions to the as-built plans to accurately reflect the as-constructed conditions. The most significant of these issues is the new easement required on the Dever property where the location of the sewer main was revised by the developer.