PENNONI ASSOCIATES INC.
CONSULTING ENGINEERS

THRN 01 00
October 26, 2017

ENGINEER'S REPORT

REGARDING WASTEWATER ISSUES
November 1, 2017

East Side Sewer District

– Chemical Storage Tank @ WWTP

- The 1025 gallon tank housing the chemical required for phosphorus removal has developed a leak. The leak at this time is relatively minor, contained and does not present a hazard. The issue however will have to be addressed in the near future. We will work with Township staff and DELCORA to determine the most practical and cost effective solution.

– Thornton Road Low Pressure Sewer

- A response letter addressing comments on the planning module was forwarded to DEP on October 16th. To date, we have received no further correspondence from DEP on the application. Also, a preliminary plan for the main extension has been prepared and will be distributed to the Township and Sewer Committee next week for review and comment.

West Side Sewer District

– Mill Creek Subdivision

- At this time, all construction related items contained in our punch list dated 10/1/13 have been addressed. The outstanding issues consist solely of revisions to the as-built plans to accurately reflect the as-constructed conditions. The most significant of these issues is the new easement required on the Dever property where the location of the sewer main was revised by the developer.