



CITY OF PLACERVILLE, CALIFORNIA

DEVELOPMENT SERVICES DEPARTMENT ENGINEERING DIVISION

MADRONE AND GIOVANNI SEWER LIFT STATIONS REHABILITATION PROJECT CITY PROJECT No. 40330

ADDENDUM No. 2
September 26, 2017

This addendum shall become a part of the Contract Documents (Proposal, Measurement and Payment, Plans, and Pothole Data) and modify them as stated below. The Bidder shall acknowledge receipt of the addendum on Page 4 of the Proposal.

The Contract Documents have been modified as follows:

CHANGES AND/OR CLARIFICATIONS TO THE NOTICE TO BIDDERS:

1. Bid Opening for this project is **rescheduled to Thursday, October 5th, 2017 at 4 pm.**

One additional addendum will be issued prior to bid opening.

Bidder Questions Received to Date:

1. *There appears to be a quantity bust on the bid schedule on page 3 of Section 00310 for item 7 "New sewer pipeline", please confirm the additional 200 feet of pipe in the schedule versus what's shown on the plans.*
 - a. The City intentionally increased that quantity to allow for additional replacement of pipe beyond what's shown on the plans. The existing condition is not fully known and having the additional quantity allows a payment mechanism in the contract for replacement as needed.

Contractors are required to base their bid on the plans, specifications and any issued addenda. To do otherwise shall be at the contractor's own risk.

END OF ADDENDUM NO. 2