



EQUIPMENT INVENTORY - Menlo Park FPD Station 2

Bldg ID	Flr #	Rm #	Asset ID	Equipment Description	Manufacturer	Model #	Serial #	Notes/Comments	Picture	Active/ Inactive	Bus Pri	Ops Pri	Fail State
											1-5 (5=Highest)		
2	Ext	E	001	Main Meter Panel	AW	N/A	N/A	200A, 120/240v, 3Ph	2-061	A	3	4	3
2	Ext	E	002	Service Disconnect	Wadsworth Elec. Mfg	3823	N/A	200A, 120/240v, 3Ph	2-061	A	3	4	3
2	Ext	N	003	BFT/ Regulator	N/A	N/A	N/A	1" service	--	A	2	2	4
2	R	Roof	004	Gas Pack	Carrier	48HJD005-331	4695G20292	4 ton, installed 1995	2-090	A	2	2	4
2	R	Roof	005	Exhaust Fan	Loren Cook	100ACEB	N/A	12"	2-089	A	1	1	3
2	R	Roof	006	Exhaust Fan	Loren Cook	100ACEB	N/A	12"	2-089	A	1	1	3
2	1	App	007	Door Operator	Power Master	T	331-2	1/2 hp	--	A	2	3	3
2	1	App	008	Door Operator	Power Master	T	331-7	1/2 hp	--	A	2	3	3
2	1	App	009	Door Operator	Power Master	T	331-8	1/2 hp	--	A	2	3	3
2	1	Jan	010	Water Heater	Bradford White	U45036FRN	FK12556402	Installed 11/'09, 50gal, natural gas	2-093	A	2	2	1
2	Ext	W	011	Gas Meter	Equimeter	415	N/A	3/4" service	2-094	A	2	2	3
2	1	App	012	Space Heater	Reznor	N/A	N/A		2-099	A	1	1	3
2	1	App	013	Sub Panel	Bulldog Electric	Pushmatic	N/A	100A, 120/240v, 1Ph	2-117	A	4	4	4
2	1	App	014	Sub Panel, SPDT manual Transfer switch	Square D	Q08-166100D	N/A	'Emergency Panel', 100A, 120/240v, 1Ph, 8 circuit	2-119	A	4	4	4
2	1	App	015	Truck Exhaust	Plymovent	N/A	N/A	2 station	--	A	2	3	3
2	Ext	E	016	Generator	Honda	FM 5000 SX	N/A	5Kw, 120/240v, 1Ph	2-071	A	2	4	4